

DOOR SCHEDULE - GUESTROOMS

DOOR #	LOCATION	TYPE	DOOR				FRAME				FIRE RATING	HW SET	REMARKS		
			WIDTH	HEIGHT	THKNS	MATERIAL	FINISH	HEAD	JAMB	SILL				MATERIAL	FINISH
G01A	GUESTROOM ENTRY	DP G	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	1	
G01B	GUESTROOM ENTRY	DP G	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	1	
G02A	GUEST BATH (SWING)	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL01	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT01	NO RATING	2	
G02B	GUEST BATH (SLIDING)	DP F SD B	3'-0"	6'-8"	1 3/8"	SCWD	EXP2-PL01	N/A	N/A	1/D010 (SIM)	N/A	EXP2-PT01	NO RATING	3	COORDINATE SLIDING DR TRACK MOUNTING HT W/ CEILING HT; FLOOR TRANSITION TO OCCUR AT PARTITION CL UNO
G03	GUESTROOM CONN	DP F	3'-0"	6'-8"	1 3/4"	SCWD	EXP2-PL01	2(2)/A711	2(2)/A711	1/D010	DF HM DA	EXP2-PT01	45 MIN.	1	

DOOR SCHEDULE - PUBLIC AREAS & BACK-OF-HOUSE

DOOR #	LOCATION	TYPE	DOOR				FRAME				FIRE RATING	HW SET	REMARKS			
			WIDTH	HEIGHT	THKNS	MATERIAL	FINISH	HEAD	JAMB	SILL				MATERIAL	FINISH	
100.1.1	VESTIBULE	ASD	9' - 9 1/8"	7' - 9 1/2"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	PER MFR.	PER MFR.	ASD	CLR ANODIZED	NO RATING	5	AUTOMATIC SLIDING DOOR EXTERIOR
100.1.2	LOBBY/GREAT ROOM	ASD	9' - 10 3/4"	7' - 9 1/2"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	PER MFR.	PER MFR.	ASD	CLR ANODIZED	NO RATING	5	AUTOMATIC SLIDING DOOR EXTERIOR
100.3	PATIO	DP FGA	3' - 6"	7' - 9 1/2"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	PER MFR.	PER MFR.	ASD	CLR ANODIZED	NO RATING	3	
100.6.1	MEETING	DP F SD M	6' - 2"	7' - 6"	1 3/8"	SCWD	EXP2-WD02	N/A	N/A	1/D010	N/A	N/A	NO RATING	19	SLIDING DOOR, COORDINATE SLIDING DOOR TRACK MOUNTING HEIGHT WITH CEILING HEIGHT	
100.6.2	MEETING	DP F SD M	6' - 2"	7' - 6"	1 3/8"	SCWD	EXP2-WD02	N/A	N/A	1/D010	N/A	N/A	NO RATING	19	SLIDING DOOR, COORDINATE SLIDING DOOR TRACK MOUNTING HEIGHT WITH CEILING HEIGHT	
100.6.3	MEETING	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	NO RATING	16	ADD EEPH/LE VIEWER	
100.6.4	MEETING	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL01	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	16	ADD EEPH/LE VIEWER	
100.6.5	MEETING	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL01	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	17		
100.6.6	MEETING	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL01	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	17		
100.7.1	BREAKFAST	DP PSD WD	2 @ 2' - 11"	7' - 6"	1 3/8"	SCWD	EXP2-WD02	PER MFR.	PER MFR.	N/A	DF PSD	EXP2-WD02	NO RATING	22	SLIDING POCKET DOORS	
100.7.2	BREAKFAST	DP PSD WD	2 @ 2' - 11"	7' - 6"	1 3/8"	SCWD	EXP2-WD02	PER MFR.	PER MFR.	N/A	DF PSD	EXP2-WD02	NO RATING	22	SLIDING POCKET DOORS	
100.8.1	PANTRY	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL01	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	6	PARALLEL ARM CLOSER W/ COMPRESSION STOP HOLD-OPEN	
100.8.2	PANTRY	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	18		
100.9	STORAGE	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	17		
100.10	BREAK	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	17		
100.11	MECHANICAL	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	12	PANIC HARDWARE REQUIRED	
100.13.1	SALES	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT	
100.13.2	SALES	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT	
100.14.1	WORK AREA	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	18		
100.14.2	WORK AREA	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	24		
100.15	GENERAL MANAGER	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT	
100.16	SERVER	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	NO RATING	17		
100.18.1	LAUNDRY	DP F	4' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	17		
100.18.2	LAUNDRY EQUIPMENT	DP F	2' - 0"	6' - 8"	1 3/4"	HM	EXP2-PT30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	NO RATING	16		
100.19	GUEST LAUNDRY	DP FG	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	15		
100.20	FITNESS	DP FGA	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	15		
100.21.1	POOL	DP FGA	3' - 0"	6' - 8"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	1/D010	SF	CLR ANODIZED	NO RATING	9		
100.21.2	POOL	DP FGA	3' - 0"	6' - 8"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	1/D010	SF	CLR ANODIZED	NO RATING	25		
100.22	STORE	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	18		
100.23.1	ELECTRICAL	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PT30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	90 MIN.	12	PANIC HARDWARE REQUIRED	
100.23.2	ELECTRICAL	DP F	4' - 0"	6' - 8"	1 3/4"	HM	INT. EXP2-PT30; EXT. TO MATCH EIFS (1C/1N)	1/A711	1/A711	1/D010	ALUM. SADDLE	DF HM 00	EXP2-PT30; EXT. TO MATCH EIFS (1C/1N)	NO RATING	13	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL; PANIC HARDWARE REQUIRED
100.25	LUGGAGE STORAGE	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PT30	1/A711	1/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	18		
C101	CORRIDOR	DP FGA	3' - 6"	6' - 8"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	9		
C102	CORRIDOR	DP FGA	3' - 6"	6' - 8"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	9		
C103	ELEVATOR LOBBY	DP FGA	3' - 6"	6' - 8"	PER MFR.	ALUM.	CLR ANODIZED	PER MFR.	PER MFR.	ALUM. SADDLE	SF	CLR ANODIZED	NO RATING	9		
C104	POOL VESTIBULE	DP FG	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	15	CODE REQUIREMENTS MUST BE MET FOR MAXIMUM GLAZING LITE SIZE & LOCATION	
PEQ1.3	POOL EQUIPMENT	DP F	3' - 0"	6' - 8"	1 3/4"	HM	EXP2-PT30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	17		
R1	TOILET - WOMENS	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	23		
R2	TOILET - MENS	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	20 MIN.	23		
R3	UNISEX EMPLOYEE RR	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	14	PROVIDE THROW DEADBOLT/LATCHBOLT	
ST1.1.1	STAIR 1	DP N	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED; PROVIDE MAGNETIC HOLD-OPEN W/ AUTO RELEASE UPON ACTIVATION OF FIRE ALARM	
ST1.1.2	STAIR 1	DP F	3' - 0"	6' - 8"	1 3/4"	HM	INT. EXP2-PT30; EXT. TO MATCH EIFS (3C/3N)	2(1)/A711	2(1)/A711	1/D010	ALUM. SADDLE	DF HM 00	INT. EXP2-PT30; EXT. TO MATCH EIFS (3C/3N)	NO RATING	21	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL; PANIC HARDWARE REQUIRED
ST2.1.1	STAIR 2	DP N	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	90 MIN.	20	PANIC HARDWARE REQUIRED; PROVIDE MAGNETIC HOLD-OPEN W/ AUTO RELEASE UPON ACTIVATION OF FIRE ALARM	
ST2.1.2	STAIR 2	DP F	3' - 0"	6' - 8"	1 3/4"	HM	INT. EXP2-PT30; EXT. TO MATCH EIFS (4C/4N)	2(1)/A711	2(1)/A711	1/D010	ALUM. SADDLE	DF HM 00	INT. EXP2-PT30; EXT. TO MATCH EIFS (4C/4N)	NO RATING	21	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL; PANIC HARDWARE REQUIRED
100.24	WATER HEATER	DP F	4' - 0"	6' - 8"	1 3/4"	HM	INT. EXP2-PT30; EXT. TO MATCH EIFS (1C/1N)	1/A711	1/A711	1/D010	ALUM. SADDLE	DF HM 00	INT. EXP2-PT30; EXT. TO MATCH EIFS (1C/1N)	NO RATING	13	EXTERIOR DOOR AND FRAME COLOR TO MATCH ADJACENT EXTERIOR WALL
CH1	CHUTE CLOSET	DP F	3' - 0"	6' - 8"	1 3/4"	SCWD	EXP2-PL30	2(1)/A711	2(1)/A711	1/D010	DF HM 00	EXP2-PT30	45 MIN.	7		

DOOR HARDWARE GROUPS AND FINISHES.

Hardware finishes and base metals shall be listed below, unless otherwise indicated.

Refer to IHG Approved Electronic Door Lockset Guide for list of approved electronic door locksets and information on required finish, fixtures and trim.

Satin stainless steel (US32D) and satin chromium plated (US26D). Finishes and base metals, unless otherwise indicated.

- Exterior Hinges - US32D on stainless steel.
- Interior Hinges - US26D on steel.
- Flush Bolts - US26D on brass or bronze.
- Manual Locks - US32D on stainless steel.
- Electronic Locks - See IHG Electronic Door Locks Guide.
- Exit Devices - 33 Series Sprayed Aluminum.
- Exit Devices - 99 Series Sprayed Aluminum.
- Pulls, Push Plates/Bars - US32D on stainless steel.
- Door Holders - USP on stainless steel.
- Door Closers - 3 Series Sprayed Aluminum.
- Vertical Sliding Door Holders - US32D on brass or bronze.
- Kickplate - US32D on stainless steel.
- Door Edge Guards - US32D on stainless steel.
- Armor Plates - US32D on stainless steel.
- Stops, Holders - US26D on brass or bronze.
- Thresholds - Milled Aluminum.
- Miscellaneous - US26D on brass or bronze.

Hardware on aluminum doors shall match finish of doors and frame.  
 1. US32 and US32D solid 18-8 chromium-nickel, 300 Series, "Austenitic", non-magnetic.  
 2. Straight chrome-ions (magnetic) are not acceptable, except as hinge pins.  
 3. For items not available in US32 or US32D provide US26 or US26D.

Door Hardware Groups.

SET 1 - Guestroom Entrance door  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches. Power transfer type hinges.  
 Lockset/Function: Electronic mortise lockset with throw deadbolt / dead-locking latchbolt on interior room side.

Card Reader: RFID card reader entry. Refer to IHG Approved Electronic Door Locksets Guide.  
 Privacy Door Latch: Cannot be used to keep door ajar. Can be legally installed on fire-rated openings.  
 Closer: Parallel arm closer with appropriate mounting and cover. 1 Req'd.  
 Stop: Floor Stop or Wall Stop, 1 Req'd; Floor Stop, 1 Req'd. In lieu of wall stop where indicated in enlarged Guestroom sheets, A410-A422

Gaskets: Smoke / Acoustical Gaskets - minimum triple-fin, self-adhering gasketing, similar to National Guard Products (NGP) 5075B, or DHSI 105 "Cush N Seal"  
 Accessories: Swing door gasket. Door viewer - standard (160 degree) door viewer, UL Listed glass lens with manufacturer-provided privacy cap, 1 each per door, for ADA room 2 each per door.  
 All finishes to be US32D / US26D.  
 Bottom Seal: Light-blocking 1/2" neoprene door sweep.  
 Door sweep: Neoprene with 1/2-inch sweep at door bottom.  
 Note: Provide Stone or PVC.

SET 2 - Guestroom bathroom hinged door  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches.  
 Lockset/Function: Privacy, Bathroom or Bedroom Function ANSI F76, privacy push button. Inside button locks outside lever.

Stop: Floor Stop or Wall Stop, 1 Req'd.  
 Door Silencers: 3 door silencers.  
 Accessories: Coat hook, 1 per door.  
 SET 3 - Guestroom Bathroom sliding door  
 Track: Pemko sliding 200 series track, wheel assembly with cushioned stops, bottom guide and fascia.  
 Pulls: Stainless Steel 36" long vertical door pulls, 2 Req'd.

SET 4 - Guestroom connecting pair of single swing doors  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches.  
 Lockset/Function: Mortise lockset with passage function, with throw deadbolt on interior room side.  
 Lever on interior room side only. Provide blank plates with no access to screws on non-guestroom side of door.

Stop: Floor Stop, 2 Req'd.  
 Gaskets: Smoke / Acoustical Gaskets - minimum triple-fin, self-adhering gasketing, similar to National Guard Products (NGP) 5075B, or DHSI 105 "Cush N Seal"  
 Door sweep: Light-blocking 1/2-inch neoprene door sweep.  
 Threshold: Stone or PVC. Single continuous threshold spanning between both doors.  
 SET 5 - Automatic sliding entrance doors  
 Hardware provided by door manufacturer, provide cylinder lock for integration into exterior door.  
 Similar to BESAM markings for Emergency Breakaway functions as required by code and as provided by manufacturer. Provide wall-mounted RFID reader & intercom, and ability to unlock door remotely from front desk.

SET 6 - Pantry service door  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches.  
 Lockset/Function: Electronic mortise lockset with free access on interior room side.  
 Card Reader: RFID card reader entry. Refer to IHG Approved Electronic Door Locksets Guide.  
 Closer: Adjustable parallel arm closer with appropriate mounting and cover. 1 Req'd.  
 Stop: Overhead Compression Stop, 1 Req'd.  
 Plates: Stainless Steel 10" high kickplate both sides of door.  
 Gaskets: Fire, 1 set for single leaf door.

SET 7 - Linen Chute Room door  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches.  
 Lockset/Function: Electronic mortise lockset.  
 Card Reader: RFID card reader entry. Refer to IHG Approved Electronic Door Locksets Guide.  
 Closer: Adjustable parallel arm closer with appropriate mounting and cover. 1 Req'd.  
 Stop: Wall Stop or Overhead Stop, 1 Req'd.  
 Plates: Stainless Steel 10" high kickplate both sides of door.  
 Gaskets: Fire, 1 set for single leaf door.

SET 8 - Exterior exit door in storefront framing  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches.  
 Lockset/Function: Entrance Function ANSI F81, keyed on exterior side with privacy turn button on interior side.  
 Exit Device: Rim type Exit device.  
 Closer: Adjustable parallel arm closer with appropriate mounting and cover. 1 Req'd.  
 Stop: Overhead Stop, 1 Req'd.  
 Gaskets: Weatherstripping, 1 set for single leaf door.

SET 9 - Exterior exit door in frame w/sideglint and exterior guest access  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches. Power transfer type hinges.  
 Lockset/Function: Electronic latchset for RFID card reader entry.  
 Exit Device/Security/Card Reader: Rim type Exit device. Electronic latchset for wall-mounted weather proof RFID card reader entry.  
 Closer: Adjustable parallel arm closer with appropriate mounting and cover. 1 Req'd.  
 Door sweep: Neoprene with 1/2-inch sweep at door bottom.  
 Threshold: Aluminum 5-inch saddle, 1/2-inch high.  
 Note: Pool Room exterior door does not require exterior guest access (no electronic latchset and no RFID card reader entry).

SET 10 - Electrical Closet double doors  
 Hinges: Qty 3 per leaf 4-1/2 by 4-1/2-inches.  
 Lockset/Function: Electronic mortise lockset on operable leaf. Flush bolts with dust-proof strike on inactive leaf. Provide astragal where required by the door manufacturer.  
 Card Reader: RFID card reader entry. Refer to IHG Approved Electronic Door Locksets Guide.  
 Closer: Adjustable parallel arm closer